



Additional Fire Safety Requirement for Food Room

食物间附加消防安全规定

In view of the cooking utensil and the intended cooking activities being noted vide the submitted layout plan, the Food Room should be treated as a Kitchen and be separated from the remaining parts of the food premises to the standard as stipulated by the Building Authority. As a general guideline, this shall be effected by brick walls of not less than 100mm thick or equivalent to give a FRP of one hour; and any door opening giving onto the Food Room protected by self-closing door or equivalent to give a FRP of one hour.

根据你所提交的图则，发现有煮食用具及煮食活动在食物间内进行，食物间应被视作厨房，及须按照建筑事务监督所规定的厨房标准把食物间与食肆内的其他部份分隔。根据一般准则，须使用厚度不少于 100 毫米的砖墙或相等效能的物料把食物间与食肆内的其他部份分隔，以提供壹小时的抗火时效；而任何通往食物间的门口须以自掩门或相等效能的物料保护，以提供壹小时的抗火时效。

(1st revision) (第 1 修订版)